

CUSTOMER		TOR ONSHUS	
REFERENCE NUMBER		04230455.0100 7052554	
Product type		Serial number	
DCS402.0050 REV.A.1		7052554A1341925	
PARTS	CODE & VERSION	SERIAL NUMBER	
SDCS-CON3_A	3ADT312000R0001	31200001D1270217	
SDCS-FIS3_A	3ADT312100R0001	31210001A1190360	
SDCS-PIN3_A	3ADT312200R0001	31220001A1040034	
DCS400-PAN	3ADT310700R0001	22007703A131A141	
Firmware	3ADT402270R0008	40227008 108.0	
1. VISUAL INSPECTION		APPROVED	
Inspection of material and components		OK	
Inspection of clearance and creepage distance		OK	
Inspection of terminals, boards an conexions		OK	
2. INSULATION TEST			
Fan	2.0 kVAC 1 min	OK	
Main circuit	2.0 kVAC 1 min	OK	
Auxiliary circuits	1.5 kVAC 1 min	OK	
3. FUNCTIONAL PRETESTS			
Checking of fan		OK	
Checking of the temperatur measurement		OK	
Low current test		OK	
Checking of snubber circuits		OK	
4. FUNCTIONAL TESTS			
Main circuit :			
A. Nominal voltage test		OK	
B. rated current test		OK	
Field circuit :			
Rated current test		OK	
Inspected by	Date	Time	
SCHMIDT	28.08.01	06:11	